



Kenya Ports Authority

P. O. Box 95009 - 80104 Mombasa, Kenya.
Tel: +254 - 41 - 2112999 / 2113999
Mobile: 0720 202424 0734 221211
0720 202525 0734 312211
0720 312211 0735 337941 - 6
0722 208661 - 5
Wireless: +254 - 20 - 3575880 - 9
Fax: +254 - 41 - 2311867
Website: www.kpa.co.ke

PSM/CTC/1/01 (095) Vol. 1

23rd January, 2017

Dear Bidders,

RE: ADDENDUM NO. 1

TENDER NO. KPA/095/2016-17/EE – SUPPLY, INSTALLATION, TESTING AND COMMISSIONING OF SWITCHGEARS, TRANSFORMERS AND CABLES FOR 6 NO. RMGS AT CONTAINER TERMINAL

Pursuant to clause 10.1 of the above tender document, the Authority hereby issues the following Addendum in response to questions raised by prospective bidders:

Question 1: Kindly specify if the required switchgear for substation (T) is standalone switchgear or it will be an extension for the existing Switchgear.

Response: This will be an extension for the existing Switchgear.

Question 2: Kindly specify if the supply of DC system will be part of the contractor's scope for this tender.

Response: Supply of DC system will not be part of the contractor's scope for this tender. Please follow the scope and BoQ.

All other conditions remain the same.

Yours faithfully,


Yobesh Oyaro

Head of Procurement and Supplies
FOR: MANAGING DIRECTOR