



## Kenya Ports Authority

P. O. Box 95009 - 80104 Mombasa, Kenya.  
Tel: +254 - 41 - 2112999 / 2113999  
Mobile: 0720 202424 0734 221211  
0720 202525 0734 312211  
0720 312211 0735 337941 - 6  
0722 208661 - 5  
Wireless: +254 - 20 - 3575880 - 9  
Fax: +254 - 41 - 2311867  
Website: www.kpa.co.ke

PSM/CTC/1/01 (096) Vol. 1

3<sup>rd</sup> February, 2017

Dear Bidders,

RE: ADDENDUM NO. 2

### TENDER NO. KPA/096/2016-17/ME - REHABILITATION OF SHIMANZI OIL TERMINAL

Pursuant to clause 7.1 of the above tender document, the Authority hereby issues the following Addendum:

Bidders are requested to note the following additional mandatory requirements:

- i. The tenderer shall not participate as a joint venture or a consortium **(MANDATORY)**.
- ii. A written undertaking that on award of the contract all the works shall not be sub-contracted **(MANDATORY)**.

Questions 1: Will ZINGA Paint application include parts of beams under water and above water?

**Response: The ZINGA paint to be applied above the water line at its lowest tide.**

Questions 2: Is the Contractor expected to supply the Are the Zinc Anodes

**Response: The Zinc anode to be welded below the lowest level. The Zinc anodes will be supplied by the tenderer.**

Questions 3: Please clarify the number of pumps to be removed and whether they are currently working. Are they specifically SOT Pumps or KOT Pumps as well.

**Response: There are a total of three (3) main pumps and one (1) jockey pump. There are 2 main pumps and one jockey pump (not working) at SOT**

and one (1) main pump at KOT which has not been working. All the pumps are to be overhauled with new parts supplied by the tenderer.

Question 4: During the pre-bid site visit, the pipes were not marked.

Response: **The decommissioned product pipes are now marked.**

Extension of submission deadline: The submission deadline has been extended to **Wednesday, 15<sup>th</sup> February, 2017.**

All other conditions remain the same.

Yours faithfully,



Yobesh Oyaró  
Head of Procurement and Supplies  
**FOR: MANAGING DIRECTOR**