



Kenya Ports Authority

P. O. Box 95009 - 80104 Mombasa, Kenya.
Tel: +254 - 41 - 2112999 / 2113999
Mobile: 0720 202424 0734 221211
0720 202525 0734 312211
0720 312211 0735 337941 - 6
0722 208661 - 5
Wireless: +254 - 20 - 3575880 - 9
Fax: +254 - 41 - 2311867
Website: www.kpa.co.ke

PSM/CTC/2/01 (045) Vol. 1

7th November, 2017

Dear Bidders,

RE: ADDENDUM NO. 4

**TENDER NO. KPA/045/2017-18/EE –
RELOCATION OF SUBSTATION F AT G SECTION TO SHED A.**

Pursuant to clause 10.1 of the above tender document, the Authority hereby issues the following Addendum in response to requests for clarification:

No.	Question	Response
1.	Item No. 50 in the BoQ (SCADA System) Allow for all switchgears IEDs connection and integration to the KPA ABB SCADA system. Please provide Technical data for the same as it is not provided in the "Technical Specification" Section.	The Substation Automation System is ABB and based on the RTU540 product line. The communication protocol must be open protocol and shall support IEC60870-5-101 and IEC61850 for all levels of communication for sub-station automation.
2.	One of the mandatory requirements of this tender is Manufacturer's Authorization Letter from Schneider Electric for SM6 11K switchgears, low voltage switchgear, Generator. Shouldn't it be Schneider Electric or approved equivalent so as to give equal opportunity to other manufacturer's as this is tantamount to single sourcing.	The 11KV switchgears required in this tender are SM6 family from Schneider Electric for compatibility with existing switchgear installations and ease of maintenance.

All other conditions remain the same.

Yours faithfully,

Yobesh Oyaro
Head of Procurement and Supplies
FOR: MANAGING DIRECTOR